

Guide Specifications

Low Static Hydronic Ducted Fan Coils

HVAC Guide Specifications

Size Range: 0.91 to 15.5 kW, Nominal Cooling

1.44 to 18.5 kW, Nominal Heating

Polar Air Models: PDWA-V/P, PDWA-V/P-ECM,

PDWA-VI/PI, PDWA-VI/PI-EC

Part 1 — GENERAL INFORMATION

1.1 UNIT DESCRIPTION

Concealed ceiling mounted, chilled or chilled and hot water coil, suitable for installation with duct. Appropriate for connection to air-to-water or water-to-water heat pumps, boilers, and chillers.

1.2 QUALITY ASSURANCE

Unit shall be certified by ETL. Each coil shall be factory tested for leakage by water pressure test at 3.5 MPa for 3 minutes. Completed unit shall be air tested for leakage at 0.8 MPa for 3 minutes. The maximum working pressure is 2.0 MPa. Fan coils shall meet compliance requirements of ISO9001, and CE. All claims of capacity and sound performance shall be verified by an internationally recognized third-party testing agency.

1.3 DELIVERY, STORAGE, AND HANDLING

Unit shall be stored and handled per manufacturer's instructions.

Part 2 — PRODUCTS EQUIPMENT AND CONFIGURATION

A: General

Indoor, concealed ceiling mounted, horizontal, 2 or 4 pipe console fan coil unit complete with cooling coil or cooling and heating coils. Unit shall include AC or EC fan motor with on-off 3 speeds or modulating speed, single point primary electrical power connection (unless provided with optional electric heater), integral controller, heating, cooling, and entering coil air temperature sensors, transformer, capable of operating and capable of accommodating integrated, factory installed condensate pump. Control methods shall be available for AC and EC units. Infra-red receiver display for remote control, valves, and electric heater shall be available as optional items.

B: Unit Casing

Casing shall be constructed of galvanized steel panels with couplings for ducting and resistant to rust, corrosion, chemical agents, solvents, aliphatic compounds and alcohols. The casing shall be provided with thermal and acoustical internal insulation and mounting holes.

C: Drain Pan

Condensate drain pan shall provide positive slope and $\frac{3}{4}$ " outlet for drain pipe connection, be constructed of steel with powder finish, coated with self-extinguishing closed cell expanded polyethylene with thermal properties. Stainless steel pan shall be available as an option.

D: Coil

1. Standard unit shall be equipped with a cooling coil for installation in a 2-pipe system.
2. Additional coil shall be provided for installation in a 4-pipe system.
3. Cooling coils shall be 3, 4 or 6 rows selected to meet project requirements.
4. Heating coils shall be 1 or 2 rows, independently circuited specifically designed for hot water application.
5. Coils shall be TP2 seamless copper tubes 10mm outside diameter, mechanically expanded into corrugated hydrophilic coating aluminum fins for a permanent primary to secondary surface bond. Fin spacing shall be 12.7 fins per inch. Coil connectors shall be $\frac{3}{4}$ " female thread.
6. Each coil shall be provided with factory installed manual air vent and water purge valve.

E: Insulation

5mm thick NBR plastic foam. 10mm, 15mm or 25mm as an option.

F: Motors

1. AC motor shall be PSC, permanently lubricated type with internal thermal overload protection.
2. High efficiency EC motors shall be enclosed with thermal overload protection and sealed, permanently lubricated bearings. Motors shall be controlled via a factory installed electronic controller. Motors shall be constant torque, permanent magnet, brushless DC motor (EC motor only) with 3 speed or variable speed modulation functionality.
3. Fan motor shall be IP40 Class B.

G: Fan Section

The fan section shall include 1, 2, 3 or 4 galvanized steel centrifugal fans consisting of forward curved, double air inlet blades directly attached to the EC motor. Fans shall be statically and dynamically balanced.

H: Control Options

1. FULL CONTROL OPTION (I/S Type): Microprocessor controller shall control fan motor, water valves (ON/OFF or modulating valve), drain pump (optional), and electric heater (optional). Controller shall be capable of changing temperature settings, fan speed and other control functions using either infrared wireless handset or programmable wired wall mounted full function pendant controller. Controller shall provide coil freeze and over heat protection using factory installed sensors, occupancy or economy mode contacts, auto restart, and error diagnostics. Controls shall include a coil sensor(s) and a room sensor to allow fans to operate when coil is chilled (during cooling mode) and heated (during heating mode). It also allows BMS control, Master-Slave control, VVW and VAV control.
2. FLEXIBLE CONTROL OPTION (W Type): Microprocessor controller shall be suitable to use with a standalone thermostat or 0-10 VDC signal from external source. Controller shall provide simplified error diagnostics, optional drain pump and electric heater control. Controller shall include a coil sensor(s).
3. TERMINAL STRIP ONLY (T Type): To be used with an external thermostat. Available for AC Motor only.

I: Condensate Pump and Float Switch (Optional)

Fan coil units shall be available with factory-installed condensate pumps and float switches controlled by onboard controllers.

J: Filters

Nylon Filters shall be 7mm thick. 7mm G4 3M HAF filter or 25mm G4 filter shall be offered as an option.

K: Electrical Requirements

Unit shall be available for 220~240V/1ph/50~60Hz power supply.

L: Electric Heat (Optional)

PTC type stainless steel electric heaters shall be provided with two thermal protection switches, one manual fuse type and one automatic reset type. Heaters shall be suitable for factory or field installation and controlled via onboard controller.

M: Safety Ratings and Performance Verification

Fan Coil Unit shall be Eurovent certified. Performance shall be confirmed by accepted third party (Eurovent for performance and sound).

N: Wall Mounted Wired Pad

A wired wall pad for communication shall be available as an optional accessory for the 'I' controller.

O: Infrared Remote Handset

An infrared handset for remote communication shall be available as an optional accessory for the 'I' controller. (A LED receiver must be installed for signal communication.)

P: Thermostat

A thermostat shall be available as an optional accessory for the "W" controller (EC motor) or "T" terminal strip (AC motor).

Part 3 – MAINTENANCE

Maintenance access shall be done by removal of cabinet for all unit components.

OFFICES

EUROPE

Calle Río Júcar Nave 6,
Pol. Ind. El Saladar,
30564; Lorquí, Murcia
contact@pghvac.com

www.pghvac.com | www.pghvac.us

HONG KONG

Office 6, 9th F, Block A.
6 On Ping St,
Shatin; Hong Kong

BOSTON

20 Walford Park Dr,
Canton, MA
02021; USA